

Fire Resistance Rating

Certificate Number: 07-270-1B

Certificate Valid from 5/24/2007 through 5/23/2008

The concrete masonry unit submitted by the manufacturer listed has been evaluated by the National Concrete Masonry Association Research and Development Laboratory for fire resistance in accordance with the code, standard, or procedure cited. The National Concrete Masonry Association certifies to the manufacturer that concrete masonry constructed in accordance with the cited code, standard, or procedure, using units representative of the submitted unit, has the fire resistance stated.


Fire Resistance Rating 1.0 Hour(s)

determined in accordance with
ACI 216.1/TMS 0216, Standard Method for Determining the Fire Resistance of Concrete and Masonry Assemblies, 1997

Manufacturer: *Allied Concrete*
Plant: *Charlottesville, VA*
Unit Description: *4" Double Corner Concrete Masonry Unit*

Equivalent Thickness: *2.6 inches*
Aggregate Type(s): *Expanded Shale Granite*

CERTIFICATION AUTHORIZATION

Signature: 
Name: *Jeffrey S. Stein, P.E.*
Title: *Manager, Research and Development Laboratory*



**NATIONAL
CONCRETE MASONRY
ASSOCIATION**

Sustainable Concrete Products for Structures and Hardscapes
13750 Sunrise Valley Drive
Herndon Virginia 20171-4662
phone 703.713.1900 # fax 703.713.1910 # website www.ncma.org